

ELECTRICAL CORD REQUIREMENTS FOR STATE HORSE SHOW

- 110 Volt outlet for tack trailer—Cord must be a #12 Gauge Heavy Duty cord, 3 wire grounded connector on each end. **Ground MUST BE ATTACHED**
- 110 Volt outlet for Campers—Cord must be a #10 Gauge Heavy Duty cord, 3 wire grounded connector where not hard wired into the trailer. **Ground MUST BE ATTACHED.** The proper UL listed adapter must be used when adapting to different plugs
- 220 Volt Outlet for Campers—Cord must be #8 Gauge Heavy Duty cord, 4 wire grounded connector where not hard wired into trailer. **Ground MUST BE ATTACHED.** The proper UL listed adapter must be used when adapting to different plugs.
- All cords must be in good condition, no tape, electrical joints or additions to cord in anyway. Maximum length of cord should not exceed 100 feet, most outlets are within 50 feet or less of all camping spots. If cord used is longer than the distance to the outlet, it must e laid out, not left rolled up in or under camper.

STATE FAIRGROUNDS ELECTRICIAN HAS FINAL SAY IN ALL CORD CONNECTIONS

Thank you

Fairgrounds' Electrician